


PROVIDE 1'-6" SQ. BY 4" THICK
CONCRETE PAD, IF SPECIFIED.



**Cover Plan
East Jordan**



**Cover Plan
Olympic Foundry**

HAND TAMP BACKFILL
AROUND TOP SECTION

AWWA C509
RESILIENT SEATED
EPOXY COATED
NRS
2" SQUARE OPERATING NUT/LEFT TURN

ACCEPTABLE VALVES:
CLOW
KENNEDY KEN - SEAL II
M & H STYLE 4067
US PIPE METROSEAL 250
MUELLER A-2360

CITY OF PORTLAND
TYPE BOX COVER

LENGTH AS REQUIRED
8" INCH PVC ONLY

GATE VALVE

MAIN

VALVE SIZE AND TYPE
AS SPECIFIED OR SHOWN
ON PLANS.

NOTES:

1. ORDER MJ GATE VALVES WITHOUT ACCESSORIES
2. PORTLAND WATER BUREAU STANDARD VALVE BOX AND COVER AS MANUFACTURED BY OLYMPIC FOUNDRY:
 - 8" CAST IRON VALVE BOX BODY/PORTLAND STYLE/#5-603A
 - 8" CAST IRON VALVE BOX LID /PORTLAND STYLE/#5-603B
 - GRIND OFF WORDS "PORTLAND OR. " LEAVE WORD "WATER".
 - BITUMINOUS COATING.
3. or EAST JORDAN 8-INCH MODEL 00366310-TOP SECTION AND 00366324-COVER

**GATE VALVE & BOX
SETTING DETAIL**

**ENGINEERING
DEPARTMENT**
1924 COUNCIL STREET
P.O. BOX 326
FOREST GROVE, OR 97116

