



(2" CARV)

NOTES:

1. VENT PIPING TO BE GALV.
2. SLOPE COPPER TUBE FROM MAIN UP TO AIR VALVE 1% MIN.
3. TUBING FROM WATER MAIN TO BOX SHALL BE ENCASED WITH 6 INCHES OF SAND



2" COMBINATION AIR & VACUUM VALVE

\\w2k\eng\Eng Dept\STANDARD DETAILS\WATER\2 INCH CARV.DWG

ENGINEERING
DEPARTMENT
1924 COUNCIL STREET
P.O. BOX 326
FOREST GROVE, OR 97116

DRAWING NO.
402

SCALE
NONE

LAST REV. 7/18/22