



**NOTES:**

1. MAINLINE PIPE TO CONFORM TO AWWA C151 CLASS 52 AND SHALL BE CEMENT- MORTAR LINED AND SEAL COATED.
2. CITY OF FOREST GROVE WATER LINE CORROSION CONTROL METHOD IS AS FOLLOWS:
  - A. FULL 3/4"-0" ROCK ENCASEMENT EXTENDING A MINIMUM OF 6 INCHES IN ALL DIRECTIONS FROM OUTERMOST PORTIONS OF PIPE EXTERIOR.
  - B. SERVICES SHALL HAVE FULL SAND ENCASEMENT TO PROTECT PIPING.

**WATER PIPE BEDDING DETAILS**

**ENGINEERING  
DEPARTMENT**  
1924 COUNCIL STREET  
P.O. BOX 326  
FOREST GROVE, OR 97116

**city of  
forest  
grove**